



211200100034

正本



中国认可
国际互认
检测
TESTING
CNAS L4160



检验检测报告

Test Report

(2025) GJT 检 JY 字 第 00765 号

产品名称:

Product Name: 可曲挠橡胶接头

受检单位:

Inspected Body: /

生产单位:

Supplier: 安徽科力阀业有限公司

委托单位:

Client: 安徽科力阀业有限公司

检验类别:

Kind of Test: 委托检验

安徽国金检测技术有限公司

AnHui GuoJin Testing Technology Co.,Ltd



211200100034

中国认可
国际互认
检测
TESTING
CNAS L4160安徽国金检测技术有限公司
AnHui GuoJin Testing Technology Co.,Ltd

检验检测报告

Test Report

(2025)GJT 检 JY 字 第 00765 号

共 2 页 第 1 页

产品名称 Product Name	可曲挠橡胶接头	规格型号 Model/Type	DN200 PN10
受检单位 Inspected Body	/	商标 Trade Mark	安科
		检验类别 Kind of Test	委托检验
生产单位 Manufacturer	安徽科力阀业有限公司	样品等级 Sample Grade	/
抽样地点 Sampling Site	/	到样日期 Receipt Date	2025-11-27
样品数量 Samples Quantity	1 台	抽样日期 Sampling Date	/
抽样基数 Sampling Base	/	检验项目 Test Items	共壹项, 详见附页
样品特性和状态 Sample Character And Condition	见所附图片	原编号或生产日期 Serial Number/ Manufactured Date	/
委托单位 Client	安徽科力阀业有限公司	抽样单位 Sampling Body	/
委托单位地址 Client Address	铜陵市义安经开区	检验日期 Test Date	2025-11-27
抽样人员 Sampling Staff	/	检查封样人员 Checking and Sealing Samples	/
检验依据 Test Criteria	GB/T 13927-2022		
检验结论 Test Conclusion	该样品按 GB/T 13927-2022 标准检验, 所检项目合格 (检验报告专用章) 签发日期: 2025 年 11 月 28 日		
备注 Note	1、现场检测; 2、样品信息由委托人提供, 委托人对样品信息的真实性负责		

批准:
Approved by:

陈香琴

审核:
Audited By:

姜开成

主检:
Tested By:

曹克龙

安徽国金检测技术有限公司
AnHui GuoJin Testing Technology Co.,Ltd

检验检测报告附页
Test Report

(2025)GJT 检 JY 字 第 00765 号

共 2 页 第 2 页

序号	检 验 项 目	检 验 方 法	技 术 要 求	检 验 结 果	单 项 判 定
1	液体壳体试验 (1.5MPa, 120s)	GB/T 13927-2022	不应有结构损伤；不应有可见的液滴或表面潮湿。	无结构损伤；无液滴和表面潮湿。	合格



以 下 空 白

技术部
专用
02051

注 意 事 项

1. 报告无“检验专用章”或检验单位公章无效。
 2. 未经本公司书面批准，不得复制检验报告(完整复制除外)。
 3. 报告无主检、审核、批准人签章无效。
 4. 报告涂改无效。
 5. 送样委托检验，仅对来样负责。
 6. 未经本公司书面许可，本报告不得用于任何广告宣传。
 7. 在接到报告一个月之内，请来我公司办理退样手续，逾期按无主处理。
 8. 对监督性质的各类抽查和仲裁检验或质量鉴定的检验报告若有异议，应于收到报告之日起十五日内向实施监督抽查的市场监督管理部门或其上级市场监督管理部门申请复查，逾期不予受理。
 9. 本报告解释以中文为准。
 10. 本公司为原安徽国家铜铅锌及制品质量监督检验中心。
- 地址：铜陵市经济技术开发区翠湖五路 1991 号
邮编：244000 电话：0562-2686564
网址：<http://www.chinatqx.cn>

REMARK

1. The test report is invalid if there are not the marks of the special-purpose stamps for test or the testing laboratory's official stamps.
 2. The test report shall not be reproduced except in full, without approval of testing laboratory.
 3. The test report is invalid without the signatures of authorized personnel who tested, audited, and approved it.
 4. The test report is invalid if altered.
 5. As to entrusted tests, the results presented in the test reports relate only to the received samples.
 6. The test report shall not be used for advertisements or other publicity purposes, without written approval of the testing laboratory.
 7. Please take back the samples within one month after receiving the test report. If the time limit is exceeded, the testing laboratory shall handle them at will.
 8. As to supervision tests (such as spot tests, arbitration tests) or quality identification tests, if there is any objection to the test reports, please apply to the market supervision and administration that carried out them or the superior for testing again within 15 days after receiving the test reports. If the time limit is exceeded, the testing laboratory shall not accept the cases.
 9. In case of discrepancy, the original version in Chinese shall prevail.
 10. Our company is the former Anhui National Copper, Lead, Zinc and Product Quality supervision and Inspection Center.
- Address: No. 1991, Cuihu Fifth Road, Tongling Economic and Technological Development Zone
Post Code: 244000 Telephone: 0562-2686564
Web Site: <http://www.chinatqx.cn>